

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7300-0801:212 Page 1 of 1

**CATEGORY:** Misc. Device/Control Unit Accessories

**LISTEE:** Radionics, Div. Detection Systems Inc., 130 Perinton Pkwy, Fairport, NY 14450-9199 Contact: Frank Mioduszewski (716) 223-4060

**DESIGN:** Models D9133TTL-E Network Interface Module and C900TTL-E Dialer Capture Module. Units is intended for use with Model D6600 receiver for capturing alarm and event data from dialer based alarm control panels. Refer to listee's data sheet for additional detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, NFPA 72, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as control unit accessories for use with listee's separately listed Model D6600 DACR (CSFM Listing No. 7300-0801:211) and Models D7212, D7412, D9112, D9412, \*D7412G or \*D9412G fire alarm control units. Model C900TTL-E may also be used with separately listed compatible fire alarm control units. Approved for central station fire alarm signaling only.

\*Rev. 08-13-2002 TR



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **AUGUST 13, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy  
Program Manager